

## Village of Hebron

### ANNUAL DRINKING WATER QUALITY REPORT FOR THE PERIOD OF JANUARY 1 TO DECEMBER 31, 2023

This report is intended to provide you with important information about your drinking water and the efforts made by the HEBRON water system to provide safe drinking water. The source of drinking water used by HEBRON is Ground Water.

**For more information regarding this report,  
contact Dan Nelson at 815-648-2353**

Source	Water Information:
Well 4	Ground Water
Well 5	Ground Water

Este informe contiene información muy importante sobre el agua que usted bebe. Tradúzcalo ó hable con alguien que lo entienda bien.

#### Source of Drinking Water:

The sources of drinking water (both tap water and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs, and groundwater wells. As water travels over the surface of the land or through the ground, it dissolves naturally occurring minerals and, in some cases, radioactive material, and can pick up substances resulting from the presence of animals or from human activity.

#### Contaminants that may be present in source water include:

**Microbial contaminants**, such as viruses and bacteria, which may come from sewage treatment plants, septic systems, agricultural livestock operations and wildlife.

**Inorganic contaminants**, such as salts and metals, which can be naturally occurring or result from urban storm water runoff, industrial, or domestic wastewater discharges, oil and gas production, mining, or farming.

**Pesticides and herbicides**, which may come from a variety of sources such as agriculture, urban storm water runoff, and residential uses.

**Organic chemical contaminants**, including synthetic and volatile organic chemicals, which are by-products of industrial processes and petroleum production, and can also, come from gas stations, urban storm water runoff, and septic systems.

**Radioactive contaminants**, which can be naturally occurring or be the result of oil and gas production and mining activities.

- Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the EPA's Safe Drinking Water Hotline at (800) 426-4791. - In order to ensure that tap water is safe to drink, EPA prescribes regulations which limit the amount of certain contaminants in water provided by public water systems. FDA regulations establish limits for contaminants in bottled water, which must provide the same protection for public health. - Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. EPA/CDC guidelines on appropriate means to lessen the risk of infection by Cryptosporidium and other microbial contaminants are available from the Safe Drinking Water Hotline (800-426-4791). - If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. We cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline or at <http://www.epa.gov/safewater/lead>

#### Source Water Assessment:

We want our valued customers to be informed about their water quality. If you would like to learn more, please feel welcome to attend any of our regularly scheduled meetings. The source water assessment for our supply has been completed by the

Illinois EPA. If you would like a copy of this information, please stop by Village Hall or call our water operator at 815-648-2353. To view a summary version of the completed Source Water Assessments, including: Importance of Source Water; Susceptibility to Contamination Determination; and documentation/recommendation of Source Water Protection Efforts, you may access the Illinois EPA website at <http://www.epa.state.il.us/cgi-bin/wp/swap-fact-sheets.pl>.

**Source of Water:** HEBRON Based on information obtained in a Well Site Survey, published in June 1989 by the Illinois EPA, thirty-four former or current potential sources or possible problem sites were identified within the survey area of Hebron. However, based on recent information provided by the Village of Hebron, the following potential sources or possible problem sites have been removed or are no longer present: below-ground petroleum storage tank at Hebron Fire and Rescue; Sandcast Metal Works; Finish Line Furniture Refinishing; Ellison Industries (metal plating); Hebron Laundry; Jacobson's Hardware; Spooner's Art Supplies; Federal Telecom; ESB Enterprises and Kenosha Beef. The site data includes thirty-four potential sources or possible problem sites identified within the survey area of Hebron's wells. These 34 sites can be generally grouped into the following categories: manufacturing, retail/wholesale activities, machine shops, antique shops, automotive sales/repair operations, printing shops, warehouses, below ground fuel storage. The Illinois EPA has determined that the source water obtained from Hebron's Wells #4 and #5 is susceptible to contamination. This determination is based on a number of criteria including monitoring conducted at the wells; monitoring conducted at the entry point to the distribution system, and the available hydrogeologic data on the wells.

### Regulated Contaminants Detected:

- Action Level (AL): The concentration of a contaminant, which, if exceeded, triggers treatment or other requirements, which a water system must follow.
- Action Level Goal (ALG): The level of a contaminant in drinking water below, which there is no known or expected risk to health. ALG's allow for a margin of safety.

### Lead & Copper

Lead & Copper	Date Sampled	MCLG	Action Level (AL)	90th Percentile	# Sites Over AL	Units	Violations	Likely Source of Contamination
Copper	2023	1.3	1.3	0.23	0	ppm	N	Erosion of natural deposits; Leaching from wood preservations; Corrosion of household plumbing systems.
Lead	2023	0	15	1.5	0	ppb	N	Corrosion of household plumbing systems. Erosion of natural deposits.

### Coliform Bacteria

Maximum Contamination Level Goal	Total Maximum Contamination Level	Highest # of Positive	Fecal Coliform or E. Coli Maximum Contamination Level	Total # of Positive E. Coli or Fecal Coliform Samples	Violations	Likely Source of Contamination
0	1 Positive monthly sample	1		0	N	Naturally present in the environment

### Water Quality Test Results:

Definitions: The following tables contain scientific terms and measures, some of which may require explanation.

Maximum Contaminant Level (**MCL**): The highest level of contaminant that is allowed in drinking water. MCL's are set as close to the Maximum Contaminant Level Goal as feasible using the best available treatment technology. Maximum Contaminant Level Goal (**MCLG**):

The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLG's allow for a margin of safety. **ppm**: milligrams per litre or parts per million - or one ounce in 7,350 gallons of water. **ppb**: micrograms per litre or parts per billion - or one ounce in 7,350,000 gallons of water. **na**: not applicable. **Avg**: Regulatory compliance with some MCLs is based on running annual average of monthly samples. Maximum Residual Disinfectant Level (**MRDL**): The highest level of disinfectant allowed in drinking water. Maximum Residual Disinfectant Level Goal (**MRDLG**): The level of disinfectant in drinking water below, which there is no known or expected risk to health. MRDLG's allow for a margin of safety.

### Inorganic Contaminants:

Regulated Contaminates	Collection Date	Highest Level Detected	Range of Levels Detected	MCLG	MCL	Units	Violations	Likely Source of Contamination
Chlorine	2023	0.7	.5-.78	MRDLG=4	MRDL=4	ppm	N	Water additive used to control microbes
Haloacetic Acids (HAA5)	9/13/2023	3	2.94-2.94	No goal for the total	60	ppb	N	By-product of drinking water disinfection
Total Trihalomethanes (TTHM)	9/13/2023	7	6.7-6.7	No goal for the total	80	ppb	N	By-product of drinking water disinfection
Barium	10/19/2021	0.096	.09-.096	2	2	ppm	N	Discharge of drilling wastes, discharge from metal refineries; erosion of natural deposits
Fluoride	10/19/2021	0.79	.614-.79	4	4	ppm	N	Erosion of natural deposits; Water additive which promotes strong teeth; discharge from fertilizer and aluminum factories.
Iron	10/19/2021	0.58	0-.58		1	ppm	N	This contaminant is not currently regulated by USEPA. However, the state regulates. Erosion of natural deposits.
Manganese	10/19/2021	68	4.6-68	150	150	ppb	N	This contaminant is not currently regulated by USEPA. However, the state regulates. Erosion of natural deposits.
Nitrate (measured as Nitrogen)	1/11/2023	2	1.6-1.6	10	10	ppm	N	runoff from fertilizer use; leaching from septic tanks, sewage; erosion of natural deposits

<b>Sodium</b>	10/19/2023	110	29-110			ppm	N	Erosion from naturally occurring deposits. Used in water softener regeneration
<b>Arsenic</b>	10/26/2023	1	1-1	0	10	ppm	N	Erosion of natural deposits; runoff from orchards; runoff from glass and electronics production wastes

**Note: The Village of Hebron did not receive any violations during this CCR reporting period.**